Seattle City Light / Energy Smart Design FUNDING CALCULATION FORM for VARIABLE SPEED DRIVES INSTALLED ON VAV FANS

See "Instruction Sheet for Variable Speed Drives on Fan System with VAV Capability" for details on how to use this form and for additional requirements.

Facility	Name		Form Completed by						
Total F	Floor Area Served by Fan		Date						
I. SA	VINGS FACTORS TAE	BLE							
Type of Project				Application				Savings Factor	
Existing Building			If rep	If replacing discharge throttling devices				0.300	
			lf ı	If replacing inlet throttling devices				0.148	
New Construction / Major Remodel			For fa	For fan motors of 10 horsepower or less				0.148	
II. AN	INUAL ENERGY SAVI	NGS							
line	Manufacturer / Model Number		col. a	col. b	col. c	col. d	col. e	col. f	
		Location / Application SF: Supply F. RF: Return F	an Number	Horsepower per motor	Total rated horsepower (col. a) x (col. b)	Hours per year motor on	Savings factor (see table above)	Annual energy savings (col. c) x (col. d) x (col. e) (kWh/yr)	
Α									
В									
С									
D									
Е									
F									
G	Total						1		
III. F	JNDING			_		-		Ø	
Н	Estimated Seattle City Light Funding (1)			(line G, col. f) x \$0.233/kWh \$					
I	Project Cost		Cost related to the measure \$						

Seattle City Light Use Only

Note: (1) This form is not a guarantee of funding from Seattle City Light. The estimated funding will be reviewed by Seattle City Light in relation to system performance, project costs, suitability of the equipment, control strategy, etc. Funding can only be guaranteed through written legal documents signed by Seattle City light.

Approved By:

Approved Funding Amount:

Date: